



Flexible or rigid underlay to comply with table 23 (E2/AS1 or E2/AS4), or have an applicable CodeMark or BRANZ appraisal. A thermal break is required where lightweight steel framing is used. Underlay and thermal break to be installed in accordance with the underlay or thermal break product supplier's requirements.

Sealant around pipe.

Pipe penetration sloping to outside.

Flashing tape around pipe.

Hume Pine Bevelback Weatherboard and battens to be in fixed in accordance with drawings HPCBBH (C1,C2,C3 & C4) as applicable.

Timber or lightweight steel framing that complies with the NZ building code or for existing has the equivalent stiffness to the framing provisions of NZS 3604:2011.



Hume Pine
Bevelback W-Board
Pipe penetration (flashing tape)

Version V2
Scale 1:2.5
Date: 1/11/2022
Ref: HPCBBH D12a

