



Hume Pine Bevelback Weatherboard and battens to be fixed in accordance with drawings HPCBBH (C1,C2,C3 & C4) as applicable.

Flexible or rigid underlay to comply with table 23 (E2/AS1 or E2/AS4), or have an applicable CodeMark or BRANZ appraisal. A thermal break is required where lightweight steel framing is used. Underlay and thermal break to be installed in accordance with the underlay or thermal break product supplier's requirements.

Timber or lightweight steel framing that complies with the NZ building code or for existing has the equivalent stiffness to the framing provisions of NZS 3604:2011.

Cantilever strip to suit the spacing.

Proprietary cavity closer, installed to provide a 25 mm drip edge.



Hume Pine
Bevelback W-Board
Threshold to timber subfloor

Version V2
Scale 1:2.5
Date: 1/11/2022
Ref: HPCBBH-D2b

