



Flexible or rigid underlay to comply with table 23 (E2/AS1 or E2/AS4), or have an applicable CodeMark or BRANZ appraisal.
 A thermal break is required where lightweight steel framing is used.
 Underlay and thermal break to be installed in accordance with the underlay or thermal break product supplier's requirements.

Timber or lightweight steel framing that complies with the NZ building code or for existing has the equivalent stiffness to the framing provisions of NZS 3604:2011.

Soffit lining

Hume Pine 24 x 19 mm timber moulding, H3.1, min 6 mm chamfer to internal corner

Top cavity batten as required

Hume Pine Bevelback Weatherboard and battens to be in fixed in accordance with drawings HPCBBH (C1,C2,C3 & C4) as applicable.



Hume Pine
 Bevelback W-Board
 Soffit (horizontal) junction

Version V2
 Scale 1:2.5
 Date: 1/11/2022
 Ref: HPCBBH-D3a

